

RESOLUTION NO. 2008-998

A RESOLUTION OF THE BOARD OF DIRECTORS OF VALLEY SANITARY DISTRICT OF RIVERSIDE COUNTY ESTABLISHING MAXIMUM CONCENTRATION LIMITS FOR WASTEWATER DISCHARGES TO THE VALLEY SANITARY DISTRICT WASTEWATER RECLAMATION FACILITY

WHEREAS, Order No. R7-2005-0081, NPDES Permit No. CA0104477 issued to Valley Sanitary District (referred to hereinafter as the District) by the State of California contain specific discharge limitations designed to prevent pass through and/or interference in accordance with all provisions of 40CFR403.5 and 403.6; and

WHEREAS, Waste Discharge Requirements in Order No. R7-2002-0009 issued to the District contain producer/user limitations for the use of recycled water; and

WHEREAS, the District adopted Ordinance No. 98-116 which contains local wastewater discharge limitations for commercial and industrial users; and


WHEREAS, the District intends to establish specific wastewater limitations through Resolution rather than by Ordinance to better facilitate anticipated revisions in the future; and

WHEREAS, the District is required to establish technically based and legally defensible local discharge limits to prevent pass through and/or interference in accordance with 40CFR403.5 and 403.6; and


NOW, THEREFORE BE IT RESOLVED that the Board of Directors of the Valley Sanitary District of Riverside County does hereby adopt the following maximum concentration limits of industrial wastewater pollutants listed in the attached Table I, for the Valley Sanitary Wastewater Treatment Plant in accordance with Section 208 E of District Ordinance No. 98-116, "Sewer Construction and Use Ordinance".

PASSED, APPROVED, and ADOPTED, this 12th day of November, 2008, by the following roll call vote:

AYES:	Duran, York, Wiseman, Teague, Friestad
NAYES:	None
ABSENT:	None
ABSTAIN:	None


William R. Teague, President

ATTEST:


Merritt Wiseman, Secretary/Treasurer

COPY

Table I
Valley Sanitary Wastewater Treatment Plant
Industrial Wastewater Pollutant Limitations¹

<u>Constituent</u>	<u>Concentration(mg/L)²</u>
Arsenic	4
Cadmium	0.4
Chromium	14
Copper	12
Lead	3
Mercury	0.1
Nickel	7
Silver	5
Zinc	15
Cyanide (Total)	5.0
Cyanide (Amenable)	1.0
Polychlorinated Biphenyls	0.01
Pesticides	0.01
Total Toxic Organics	2.13
Sulfide	5.0
Oil & Grease	400.0
Total Petroleum Hydrocarbons (TPH)	25.0

¹User subject to Federal Categorical Pretreatment Standards shall meet the requirements of 40CFR Chapter I Subchapter N Parts 405-471 in addition to the standards set forth above.

² Maximum concentration values are subject to review during the permitting process to determine if high flow volumes from any user at the stated concentrations would cause pass-through of pollutants which is prohibited. In such cases, a mass limit (lbs/day) would be applied.

COPY