




# **Valley Sanitary District**

## **Collection System Master Plan**

**FINAL**

June 2013

Prepared for Valley Sanitary District  
Indio, California

Prepared by MWH  
Pasadena, California

# Executive Summary

---

This Executive Summary of the Collection System Master Plan (Master Plan) for Valley Sanitary District (VSD) provides an overview of the Master Plan project. A brief description of the project background, the scope of work, existing sewer system, model creating and calibration, system evaluation, and recommended improvements and their associated costs.

## ES.1 OBJECTIVES & SCOPE OF WORK

This Master Plan has been developed under Task Authorization No. 1 between VSD and MWH Americas, Inc. (MWH) dated May 30, 2012.

The key objectives of the Master Plan are to:

- Provide an update to the 2003 Sewer Master Plan
- Create and calibrate a computer-based hydraulic model
- Evaluate the existing sewer collection system
- Address system deficiencies for existing conditions, as well as build-out and 5-year (i.e., year 2018) interim conditions.
- Develop a phased capital improvement program with an emphasis on flow, age, and material deficiencies from the hydraulic model.

The scope of work for this Master Plan consists of the following tasks:

- Task 1: Provide Project Management, Communication and Meetings
- Task 2: Data Collection and Modeling Review
- Task 3: Hydraulic Sewer Model Development
- Task 4: Flow Monitoring and Sewer Model Calibration
- Task 5: Sewer Model Analysis
- Task 6: Sewer System Improvements
- Task 7: Collection System Master Plan Report

## ES.2 BACKGROUND

The VSD service area primarily consists of residential areas with moderate commercial, industrial, and public land use encompassing much of the City of Indio, portions of the City of La Quinta and City of Coachella, and unincorporated areas of the County of Riverside. VSD provides collection system services to a population of approximately 76,000. The original Sewer Master Plan was prepared in 2003 by Dudek & Associates, Inc. Since then, growth and infrastructure improvements to support growth within the VSD service area have demonstrated the need to update the previous Sewer Master Plan. The intent of the updated Master Plan is to assist VSD in planning for near-term and build-out development. As part of the Master Plan, a sewer hydraulic model is developed to evaluate the collection system capacity for existing, near-term, as well as future flow conditions. A Capital Improvement Program (CIP) is developed based on hydraulically deficient pipes identified by the model. The purpose of the CIP is to help VSD identify the prioritized collection system infrastructure projects required to support the growth expected to occur within the VSD service area. It is recommended that VSD update this Master Plan every five years to account for changes in the growth pattern that could impact the sewer flows, which in turn could impact the infrastructure requirements.

VSD was formed in 1925 and primarily serves the city of Indio, California. The city of Indio encompasses approximately 96 percent of the VSD service area, while the remaining 4 percent is comprised of portions of the City of La Quinta and City of Coachella, as well as unincorporated land in Riverside County. VSD operates and maintains 246 miles of sanitary sewer line and delivers over 6 million gallons per day (gpd) of wastewater to its 11

million gallons per day (mgd) wastewater treatment plant (WWTP) on Van Buren Street and Enterprise Way.

**Table 2-4** shows the breakdown of generalized land use category and the percentage of area each category that occupies the existing VSD service area.

**Table 2-4  
Existing Land Use**

| <b>Land Use</b>                | <b>Area (acres)</b> | <b>Area (sq. mi.)</b> | <b>Percentage of Total Area of VSD (%)</b> |
|--------------------------------|---------------------|-----------------------|--------------------------------------------|
| Commercial                     | 617                 | 0.96                  | 4.8                                        |
| Industrial                     | 425                 | 0.66                  | 3.3                                        |
| Mixed Use                      | 119                 | 0.19                  | 0.9                                        |
| Open                           | 6,763               | 10.57                 | 52.5                                       |
| Public                         | 359                 | 0.56                  | 2.8                                        |
| Residential High               | 987                 | 1.54                  | 7.7                                        |
| Residential Low                | 2,475               | 3.87                  | 19.2                                       |
| Residential Medium             | 1,030               | 1.61                  | 8.0                                        |
| Vacant and Septic <sup>1</sup> | 107                 | 0.17                  | 0.8                                        |
| <b>Total</b>                   | <b>12,882</b>       | <b>20.13</b>          | <b>100.0</b>                               |

<sup>1</sup> : This category is not present in the Build-out Land Use (Table 2-6) as there is not anticipated to be any septic or vacant land in the projected scenario as a conservative estimate.

Population projection data is provided for each Census tract and evaluated from year 2010 through 2035 in five-year increments, as shown in **Table 2-5**. Population within the VSD service area is expected to increase almost 60 percent from year 2010 to 2035.

**Table 2-5  
Existing and Projected Population within VSD Service Area**

| <b>Year</b> | <b>VSD Population</b> |
|-------------|-----------------------|
| 2010        | 76,036                |
| 2015        | 87,486                |
| 2020        | 100,387               |
| 2025        | 106,923               |
| 2030        | 113,681               |
| 2035        | 120,676               |

**Table 2-6** summarizes land use for the build-out scenario.

**Table 2-6  
Build-out Land Use**

| <b>Land Use</b>    | <b>Area (acres)</b> | <b>Area (sq. mi.)</b> | <b>Percentage of Total Area of VSD (%)</b> |
|--------------------|---------------------|-----------------------|--------------------------------------------|
| Commercial         | 1,063               | 1.66                  | 8.25                                       |
| Industrial         | 542                 | 0.85                  | 4.21                                       |
| Mixed Use          | 777                 | 1.21                  | 6.03                                       |
| Open               | 3,574               | 5.58                  | 27.74                                      |
| Public             | 457                 | 0.71                  | 3.54                                       |
| Residential High   | 4,437               | 6.93                  | 34.45                                      |
| Residential Low    | 1275                | 1.99                  | 9.9                                        |
| Residential Medium | 758                 | 1.18                  | 5.88                                       |
| <b>Total</b>       | <b>12,882</b>       | <b>20.13</b>          | <b>100</b>                                 |

### **ES.3 EXISTING SEWER SYSTEM**

This section describes VSD's existing sewer infrastructure. The existing wastewater collection system consists of over 246 miles of pipes, 5 active pump stations, 8 siphons, and a wastewater treatment plant (WWTP). The collection system is comprised primarily of polyvinyl chloride (PVC) and vitrified clay pipe (VCP). The oldest known sewer pipes that are still in operation were connected to the system in 1935. Roughly half of VSD's pipes have been built within the last 20 years.

The collection system consists of pipes ranging from 4- to 54-inches in diameter. 8-inch or smaller diameter pipes make up roughly 75 percent of the gravity sewer system. **Table 3-1** presents the distribution of pipe sizes for the VSD collection system.

**Table 3-1  
Pipes by Diameter Summary**

| <b>Diameter (in)</b> | <b>Total Length (feet)</b> | <b>Total Length (miles)</b> | <b>Percentage of Total Length (%)</b> |
|----------------------|----------------------------|-----------------------------|---------------------------------------|
| 8 or less            | 970,454                    | 183.8                       | 75%                                   |
| 10                   | 114,208                    | 21.6                        | 9%                                    |
| 12                   | 57,873                     | 11.0                        | 4%                                    |
| 15                   | 74,482                     | 14.1                        | 6%                                    |
| 16                   | 1,271                      | 0.2                         | 0%                                    |
| 18                   | 34,681                     | 6.6                         | 3%                                    |
| 21                   | 3,942                      | 0.7                         | 0%                                    |
| 24                   | 12,491                     | 2.4                         | 1%                                    |
| 27                   | 15,439                     | 2.9                         | 1%                                    |
| 30                   | 2,730                      | 0.5                         | 0%                                    |
| 36                   | 7,113                      | 1.3                         | 1%                                    |
| 42                   | 708                        | 0.1                         | 0%                                    |
| 48                   | 3,253                      | 0.6                         | 0%                                    |
| 54                   | 117                        | <1                          | <1%                                   |
| <b>TOTAL</b>         | <b>1,298,762</b>           | <b>246.0</b>                | <b>100%</b>                           |

The VSD collection system has eight inverted siphons. All siphons in the VSD system are single barrel pipes with the exception of the triple barrel pipes crossing the Coachella Valley Water District (CVWD) stormwater channel located east of Van Buren Street and 45th Avenue. This siphon includes one 16-inch, one 20-inch, and one 24-inch diameter pipe. Based on the record drawings of this siphon, there is a fourth barrel designated for future recycled water (16-inch) which is not included in the sewer model. **Table 3-3** lists the siphons for the VSD system that are input into the sewer model.

**Table 3-3**  
**Summary of VSD Siphons**

| No. | Siphon Start Node | Siphon Stop Node | Siphon Model ID                                                                              | Diameter (in) | No. of Barrels | Location                                                                               |
|-----|-------------------|------------------|----------------------------------------------------------------------------------------------|---------------|----------------|----------------------------------------------------------------------------------------|
| 1   | 10B-M035          | 10B-M040         | 10B-M035_10B-M040                                                                            | 15            | 1              | Northeast of Jefferson St. and Highway 111                                             |
| 2   | 9C-M265           | 9C-M270          | 9C-M265_9C-M270, CDT-11                                                                      | 12            | 1              | East of Westward Ho Dr. and Spyglass Hills St.                                         |
| 3   | 6D-M115           | 6D-M120          | 6D-M115_6D-M120, CDT-21, CDT-23, CDT-25                                                      | 15            | 1              | Along Fred Waring Dr. east of Madison St.                                              |
| 4   | 5D-M072           | 5E-M005          | 5D-M072_5E-M005                                                                              | 12            | 1              | South of Indio Blvd., north west of the intersection of Jonquil Ave. and Wild Rose St. |
| 5   | 6F-M330           | 6F-M335          | 6F-M330_6F-M335                                                                              | 15            | 1              | Avenue 44 and Indio Blvd., west of Monroe St., running under Railroad tracks           |
| 6   | 6F-M030           | 6F-M205          | 6F-M030_6F-M205, CDT-17, CDT-19                                                              | 8             | 1              | Intersection of Oleander Ave. and Monroe St.                                           |
| 7   | 5G-M080           | 5G-M085          | 5G-M080_5G-M085, CDT-13, CDT-15                                                              | 8             | 1              | On Crest Ave. between Grove St. and Arabia St.                                         |
| 8   | 8J-M125           | 8J-M130          | 8J-M125_8J-M130_3, CDT-43, 8J-M125_8J-M130_2, CDT-35, CDT-45, CDT-37, CDT-29, CDT-31, CDT-33 | 16,20,24      | 3              | CVWD stormwater channel east of Van Buren St. and 45th Ave.                            |

VSD operates all 5 of the 6 pump stations within its collection system. There are two pumping units for each pump station, with varying capacity from 2 to 15 horsepower (hp). VSD's two largest pump stations are the Calhoun Pump Station at 15 hp and Barrymore Pump Station at 10 hp.

**Table 3-5**  
**Pump Stations**

| Station No. | Station Name | Year Installed | No. of Pumps | Horsepower Per Pump | Pump Capacity | Modeled (Y/N) |
|-------------|--------------|----------------|--------------|---------------------|---------------|---------------|
| 1           | Calhoun      | 2005           | 2            | 15                  | 630           | Y             |
| 2           | Carver       | 1967           | 2            | 5                   | 320           | Y             |
| 3           | Shields      | 2001           | 2            | 8.7                 | 300           | Y             |
| 4           | Vandenberg   | 2007           | 2            | 2                   | 110           | Y             |
| 5           | Barrymore    | 1979           | 2            | 10                  | 800           | N             |

## ES.4 MODEL DEVELOPMENT AND CALIBRATION

Bentley's SewerGEMS V8i, SELECTseries 2 software is used to model the VSD sewer system. SewerGEMS is a fully dynamic model based upon EPA SWMM 5 engine, and utilizes the explicit solutions of the St. Venant equations, which permits accurate analysis of reverse flows and backwater conditions. SewerGEMS can be run in the ESRI ArcGIS, Version 10 environment, which allows for a modeling system that can be fully integrated with (Geographic Information System) GIS software and permits all the advanced ArcGIS functions to be utilized. The VSD model is built using the ArcGIS integrated version of SewerGEMS. SewerGEMS includes several tools used throughout model development including ModelBuilder to construct the model using GIS asset information and LoadBuilder to allocate flow.

The process of creating the sewer model includes: utilizing an existing GIS shapefile to form a preliminary sewer network, review and verification of existing sewer facilities, establishment of bas dry weather flows, allocation of wastewater flows, and model calibration. **Table 4-10** and **Table 4-11** summarize calibration results for the modeled weekend and weekday, respectively.

**Table 4-10**  
**Weekend Day Calibration Results**

| <b>Flow Monitor Number</b> | <b>Monitor ID</b> | <b>Purpose</b> | <b>Calibration Day Average Flows (gpm)</b> | <b>Model Average Flows (gpm)</b> | <b>Difference Between Calibration Day and Flow Monitor Data (%)</b> |
|----------------------------|-------------------|----------------|--------------------------------------------|----------------------------------|---------------------------------------------------------------------|
| 1                          | 13C-M085          | Low Density    | 44.7                                       | 49.1                             | 9%                                                                  |
| 2                          | 12E-M360          | Medium Density | 69.3                                       | 75.4                             | 9%                                                                  |
| 3                          | 11F-M070          | High Density   | 48.9                                       | 57.6                             | 16%                                                                 |
| 4                          | 9G-M020           | Public         | 4.9                                        | 4.9                              | 1%                                                                  |
| 5                          | 9F-M360           | Commercial     | 43.6                                       | 43.9                             | 1%                                                                  |
| 6                          | 11J-M095          | Calibration    | 1290                                       | 1466.1                           | 13%                                                                 |
| 7                          | 10I-M140          | Calibration    | 1700.2                                     | 1518.2                           | -11%                                                                |
| 8                          | 10I-M110          | Calibration    | 519.1                                      | 638.6                            | 21%                                                                 |
| 9                          | 7I-M060           | Calibration    | 459.6                                      | 425.2                            | -8%                                                                 |
| 10                         | 7J-M055           | Calibration    | 952.8                                      | 918.1                            | -4%                                                                 |
| N/A                        | Outfall-1         | Calibration    | 4848.1                                     | 5642.8                           | 15%                                                                 |

**Table 4-11**  
**Weekday Calibration Results**

| Flow Monitor Number | Monitor ID | Purpose        | Calibration Day Average Flows (gpm) | Model Average Flows (gpm) | Difference Between Calibration Day and Flow Monitor Data (%) |
|---------------------|------------|----------------|-------------------------------------|---------------------------|--------------------------------------------------------------|
| 1                   | 13C-M085   | Low Density    | 41.9                                | 44.1                      | 5%                                                           |
| 2                   | 12E-M360   | Medium Density | 53.2                                | 56.7                      | 6%                                                           |
| 3                   | 11F-M070   | High Density   | 48.2                                | 55.3                      | 14%                                                          |
| 4                   | 9G-M020    | Public         | 7.3                                 | 7.7                       | 5%                                                           |
| 5                   | 9F-M360    | Commercial     | 39.6                                | 40.1                      | 1%                                                           |
| 6                   | 11J-M095   | Calibration    | 1212                                | 1271.8                    | 5%                                                           |
| 7                   | 10I-M140   | Calibration    | 1587.5                              | 1453.6                    | -9%                                                          |
| 8                   | 10I-M110   | Calibration    | 514.6                               | 626.1                     | 20%                                                          |
| 9                   | 7I-M060    | Calibration    | 367.8                               | 380.3                     | 3%                                                           |
| 10                  | 7J-M055    | Calibration    | 875.4                               | 828.1                     | -6%                                                          |
| N/A                 | Outfall-1  | Calibration    | 4564.2                              | 5098.7                    | 11%                                                          |

## ES.5 SEWER SYSTEM CAPACITY EVALUATION

The sewer system hydraulic model is used to assess the existing system performance. In addition to evaluating the existing system during dry weather conditions, the model is able to evaluate operation of the system during future projected flow conditions (5-year planning and build-out scenarios). Wet weather conditions were not observed during the flow monitoring period; therefore, the model is primarily based on dry weather assessment criteria.

The model is used to evaluate three different conditions: existing conditions, 5-year planning horizon, and future conditions. Future conditions attempt to model the worst-case scenario (i.e. the system under full build-out conditions). For the VSD model, the existing weekend flow is slightly greater than the existing weekday flow and is therefore considered the worst-case scenario. The criteria used to evaluate dry weather flow for all the flow conditions include:

- All modeled pipes in the existing and 5-year scenario with a d/D ratio (depth of flow in pipe divided by the pipe diameter) greater than the design criteria (d/D ratio of 0.5 or less for pipes smaller than 18 in. in diameter, ratio of 0.75 or less for pipes 18-in. or greater in diameter) are documented and reviewed
- All modeled pipes in the build-out scenario with a d/D ratio equal to or greater than 0.9 are reviewed for potential improvement

The VSD hydraulic model was used to evaluate the system deficiencies for the existing system. In order to evaluate the system, the model was run under the known existing conditions and flows, as calibrated to the flow monitoring data. Once the model was run, the maximum d/D for each pipe in the system that received flow was analyzed, and any pipes that flowed over design capacity were identified.

Pipes 18-inches or more in diameter with a d/D greater than 0.75, and pipes less than 18-inches in diameter that with a d/D over 0.50 were identified in the hydraulic model. Furthermore, any pipes with a d/D greater than 1.0 were identified as a surcharged pipe. **Table 5-1** shows the results of this analysis for each of the three scenarios for both a typical weekend day and weekday under existing conditions.

will be thickened so that it is suitable for stabilization in the anaerobic digesters. In this manner, the digester gas production level will increase substantially once a means of thickening and digester capacity are available.

At present, well over 50% of all digester gas generated at the WRF is flared as a means of disposal. A small amount of digester gas is used in winter for heating water in the boilers for the digesters to maintain temperature.

**Table 5-1  
Summary of Surcharged and Impacted Pipes**

|                                              | Existing Scenario | 5-Year Scenario | Build-out Scenario |
|----------------------------------------------|-------------------|-----------------|--------------------|
| <b>Number of Surcharged Pipes</b>            | 81                | 108             | 409                |
| <b>Number of Pipes above Design Capacity</b> | 235               | 295             | 832                |
| <b>Total Number of VSD Modeled Pipes</b>     | 3422              | 3422            | 3422               |
| <b>% of Surcharged Pipes</b>                 | 2.40%             | 3.20%           | 12.00%             |
| <b>% of Pipes above Design Capacity</b>      | 6.90%             | 8.60%           | 24.30%             |

From this process, certain areas of the system were identified as areas of concern (AOCs) for one or more of the scenarios. **Table 5-2** lists these AOCs and gives the pertinent cross streets for the impacted areas.

**Table 5-2  
Areas of Concern (AOCs)**

| <b>AOC Number</b>                                | <b>Location</b>                      | <b>Cross Street</b>                                                          |
|--------------------------------------------------|--------------------------------------|------------------------------------------------------------------------------|
| <b>Existing System Evaluation</b>                |                                      |                                                                              |
| 1                                                | Dr. Carreon Blvd/<br>Highway 111     | Dr. Carreon Blvd. from Monroe St. to Calhoun St.                             |
| 2                                                | Jackson St. and Dr.<br>Carreon Blvd. | Date St. and Arabia St. to Dr. Carreon Blvd and Jackson St.                  |
| 3                                                | Highway 111 North                    | Highway 111 and Arabia St. to Oak Ave. and Indio Blvd.                       |
| 4                                                | Avenue 48 West                       | Avenue 48 between Jefferson St. and Shields Rd. to Avenue 48 and Madison St. |
| 5                                                | Dillon Ave./ Avenue 45               | Palo Verde Ave. and Dillon Ave, ending between Avenue 45 and Interstate 10   |
| 6                                                | Palo Verde St. / Avenue 44           | Avenue 44 and Jackson St. to Palo Verde Ave. and Sonora Ave.                 |
| 7                                                | Sola St.                             | Along Sola street from Kenner Ave to El Paseo Ave.                           |
| <b>5-Year Planning Horizon System Evaluation</b> |                                      |                                                                              |
| 8                                                | Desert Grove Dr.                     | Desert Grove Dr. between Avenue 49 and Avenue 48                             |
| 9                                                | Avenue 49                            | Orchard Dr. and Avenue 49 to Desert Grove Dr. and Avenue 49                  |
| <b>Build-Out System Evaluation</b>               |                                      |                                                                              |
| 10                                               | Lago Vista                           | Lago Brezza Dr. and Armonia Ct. to Avenue 44 and Lago Vista                  |
| 11                                               | Avenue 46                            | Avenue 46 from east of Clinton St. to Monroe St.                             |

## ES.6 PIPELINE REPLACEMENT EVALUATION

This section of the Sewer Master Plan describes a pipeline replacement program for Valley Sanitary District (VSD) based on the observed condition data obtained through closed-circuit television (CCTV) and estimated condition based on age of the pipelines. This section presents a systematic, decision-making framework for prioritizing condition assessment activities, VSD's existing closed-circuit television (CCTV) assessment data, and pipeline replacement and rehabilitation prioritizations based on the CCTV data.

Pipelines are ranked according to the combined probability and consequence of failure to the community. Based on the observed condition score from the CCTV data and the consequence of failure, the numerical risk rating was calculated. The risk rating methodology allocates equal weight to the consequence of failure score and the observed or predicted condition score. While the numerical risk rating provided a basis to identify pipes for replacement and rehabilitation, it should be used in conjunction with sound engineering judgment. Therefore, in the case of pipe renewal, a modified alphabetical risk rating, **Table 6-5**, was derived from the numerical risk rating that incorporates the rationale discussed above. The highest risk ratings are at the bottom right of the table while the lowest risk ratings are at the top left of the table.

**Table 6-5**  
**Risk Rating for Pipe Renewal Prioritization**

| Risk Rating = Condition x Consequence<br>(246.7 miles of pipeline) |                                     | Condition Score (Observed or Predicted) |                        |                        |                        |                            |
|--------------------------------------------------------------------|-------------------------------------|-----------------------------------------|------------------------|------------------------|------------------------|----------------------------|
|                                                                    |                                     | 1<br>Excellent<br>(159.5.0 mi)          | 2<br>Good<br>(28.5 mi) | 3<br>Fair<br>(34.1 mi) | 4<br>Poor<br>(17.3 mi) | 5<br>Very Poor<br>(7.3 mi) |
| Consequence of Failure Score                                       | C = 1<br>Low Impact<br>(200 mi)     | 1 = G<br>(133.8 mi)                     | 2 = F<br>(20.2 mi)     | 3 = E<br>(26.9 mi)     | 4 = D<br>(13.2 mi)     | 5 = C<br>(5.9 mi)          |
|                                                                    | B = 2<br>Medium Impact<br>(16.7 mi) | 2 = F<br>(7.0 mi)                       | 4 = E<br>(3.8 mi)      | 6 = D<br>(1.8 mi)      | 8 = C<br>(2.7 mi)      | 10 = B<br>(1.4 mi)         |
|                                                                    | A = 3<br>High Impact<br>(30.0 mi)   | 3 = E<br>(18.6 mi)                      | 6 = D<br>(4.4 mi)      | 9 = C<br>(5.4 mi)      | 12 = B<br>(1.4 mi)     | 15 = A<br>(0.1 mi)         |

**Note:** The red and white dashed border represents categories which are recommended for replacement/rehabilitation. For "4=D," roughly 7.5 miles of the 13.2 miles are recommended for replacement/rehabilitation as those are the pipes that have CCTV available and where their condition has been confirmed. The remaining 5.7 miles should have CCTV footage taken in order to confirm condition and need for replacement/rehabilitation.

Based on the risk rating presented in **Table 6-5**, it is recommended that all pipelines with the ratings of A, B, or C (high risk category) be replaced or cleaned and televised according to the priorities shown in **Table 6-6**.

**Table 6-6**  
**Priority Letter Definitions**

| Priority        | Definition                                                                                                        |
|-----------------|-------------------------------------------------------------------------------------------------------------------|
| A               | Construct within 0 to 3 years                                                                                     |
| B               | Construct within 3 to 5 years                                                                                     |
| C               | Construct within 5 to 10 years, or re-evaluate priority as required.                                              |
| 4 = D (CCTV)    | Construct within 10 to 15 years                                                                                   |
| 4 = D (no CCTV) | Clean and televise within 0–3 years and reevaluate replacement/rehabilitation options                             |
| 6 = D (Fair)    | Keep monitoring the pipe that have CCTV data and televise pipelines that don't have CCTV data within 3 – 5 years  |
| D = 6 (Good)    | Keep monitoring the pipe that have CCTV data and televise pipelines that don't have CCTV data within 3 – 5 years  |
| E               | Keep monitoring the pipe that have CCTV data and televise pipelines that don't have CCTV data within 5 – 10 years |
| F               | Keep monitoring the pipe that have CCTV data and televise pipelines that don't have CCTV data within 5 – 10 years |
| G               | No action required.                                                                                               |

**Table 6-7** is a prioritized list and planning level cost of pipes to be replaced or rehabilitated ranked from the highest risk rating to the lowest risk rating. Pipes with the highest alphabetical risk rating should be replaced or rehabilitated first. Of the 246 miles of pipeline, 24.3 miles need to be replaced or rehabilitated, which is equivalent to 9.9 percent of total pipeline length. This total length of pipe that needs to be replaced includes all pipes with a Risk Rating of A, B, and C, and those where D=4 and there is CCTV available. For the D=4 category, roughly 7.5 miles have CCTV available and need replacement/rehabilitation while the remaining 5.7 miles should have CCTV footage taken in order to confirm condition.

The costs in **Table 6-7** reflect a conservative, planning level estimate of costs. This cost assumes full replacement of pipes and does not consider the savings that could be realized through rehabilitation or partial replacement of the pipe sections. Actual cost for replacement will vary depending on individual conditions.

**Table 6-7  
Pipeline Replacement Costs**

| Diameter (in)                | Cumulative Length (ft.) | Average Cost per foot (\$) | Total Cost (\$) |
|------------------------------|-------------------------|----------------------------|-----------------|
| <b>Risk Rating = A</b>       |                         |                            |                 |
| 10                           | 349                     | \$160                      | \$55,800        |
| <b>Risk Rating = B</b>       |                         |                            |                 |
| 8                            | 5,679                   | \$130                      | \$738,300       |
| 10                           | 1,388                   | \$136                      | \$188,800       |
| 12                           | 398                     | \$172                      | \$68,500        |
| 15                           | 2,696                   | \$209                      | \$563,500       |
| 24                           | 4489                    | \$315                      | \$1,414,000     |
| <b>Risk Rating = C</b>       |                         |                            |                 |
| 8                            | 37,633                  | \$129                      | \$4,854,600     |
| 10                           | 2,752                   | \$152                      | \$418,300       |
| 12                           | 5,256                   | \$179                      | \$940,800       |
| 15                           | 16,256                  | \$190                      | \$3,088,700     |
| 18                           | 6,609                   | \$259                      | \$1,711,700     |
| 24                           | 4,495                   | \$297                      | \$1,335,000     |
| 30                           | 735                     | \$405                      | \$297,700       |
| <b>Risk Rating = D (D=4)</b> |                         |                            |                 |
| 8                            | 36,194                  | \$121                      | \$4,379,005     |
| 10                           | 3,221                   | \$135                      | \$434,800       |
| <b>TOTALS</b>                |                         |                            |                 |
| Rounded (up to nearest 100)  | 128,150                 | -                          | \$20,490,100    |

Assumptions:

- All pipes 6-inches in diameter were assumed to be replaced with 8-inch pipe
- All pipes 16-inches in diameter were assumed to be replaced with 18-inch pipe
- Any pipe without verified depth information is assumed to be 8 feet deep or less. Please note this is not a conservative estimate, but it is thought to be more accurate than assuming maximum depth
- Average Cost per Foot was calculated based on total cost divided by total length. Total Cost was calculated by finding the cost for the replacement of each individual pipe based on diameter, length, and depth as defined in Table 8-1
- Total costs are rounded to the nearest hundred

## ES.7 RECOMMENDED IMPROVEMENTS


Improvements for the existing system are ordered according to the severity of the deficiency they address. Based on the hydraulic model and discussion with VSD, improvements to address capacity issues along Dr. Carreon Blvd. were identified to be a priority. Other priority improvements involve recommendations that relieve greater areas of concern (AOC). Locations of recommended improvement projects in the VSD collection system are shown on **Figure 7-1** and listed in **Table 7-1**.

**Table 7-1**  
**Recommended Improvements Summary**

| <b>Project Number</b> | <b>Project Name</b>                                   | <b>Description</b>                                                                                                           | <b>Purpose</b>                                                                           | <b>AOC Addressed</b> | <b>Phase</b> | <b>New or Upgrade</b> | <b>Operational Change</b> | <b>Size of Pipe (in)</b> | <b>Length of Pipe (ft.)</b> | <b>Total Length of Pipe (ft.)</b> |
|-----------------------|-------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------|----------------------|--------------|-----------------------|---------------------------|--------------------------|-----------------------------|-----------------------------------|
| E-1                   | Requa Interceptor                                     | Interceptor from Madison street and Highway 111 to the WWTP                                                                  | Relieve Dr. Carreon, take Shields PS offline, and service the jail expansion.            | 1, 2, 3, 12          | Existing     | New                   | No                        | 24/ 30                   | 20,906                      | 20,906                            |
| E-2                   | Avenida Esmeralda Interceptor                         | 15-inch line connecting Highway 111 to Avenue 48 via Calle Diamante                                                          | Temporary relief of Dr. Carreon Blvd.                                                    | 1                    | Existing     | New                   | No                        | 15                       | 368                         | 368                               |
| E-3*                  | Monroe Interceptor Operational Change                 | Interceptor from Fred Waring Drive and Monroe Street south to the Requa Interceptor.                                         | Take Monroe siphon offline and convey flows to the Requa Interceptor                     | 1,5,6,7              | Existing     | N/A                   | Yes                       | N/A                      | N/A                         | N/A                               |
| E-4*                  | Clinton Street Operational Change                     | Operational change to send flows north on Clinton Street to the Requa Interceptor.                                           | Relieve Dr. Carreon Blvd                                                                 | 1,5,6,7              | Existing     | N/A                   | Yes                       | N/A                      | N/A                         | N/A                               |
| E-5*                  | Shields Interceptor                                   | Line from Shields PS east to Avenue 46.                                                                                      | Take Shield PS offline                                                                   | 1                    | Existing     | New                   | No                        | 10                       | 1,427                       | 1,427                             |
| E-6                   | Avenue 48 West Upgrade                                | Upsizing of 10-inch line extending west from along Avenue 48 from Madison St.                                                | Relieve current and projected capacity issues for Avenue 48 West                         | 4                    | Existing     | Upgrade               | No                        | 15/18                    | 670/ 2,875                  | 3,545                             |
| P-1                   | Arabia Interceptor/ Jackson Street Operational Change | Bulkheading change and pipe improvements to divert flow from Dr. Carreon Blvd north to Highway 111                           | Relieve Dr. Carreon Blvd                                                                 | 1,2                  | 5 year       | New                   | Yes                       | 8                        | 850                         | 850                               |
| P-2                   | Highway 111 Interceptor                               | Pipe connecting N. Hwy 111 to the Requa Interceptor                                                                          | Relieve Dr. Carreon and increase Hwy 111 capacity in order to accommodate jail expansion | 3                    | 5 year       | Both                  | No                        | 12                       | 2,979                       | 2,979                             |
| P-3*                  | Avenue 49 Interceptor                                 | Interceptor to convey flows from Avenue 49 to Monroe Street and then north to Avenue 48                                      | Relieve Avenue 49 and Desert Grove Street                                                | 8,9                  | 5 year       | New                   | No                        | 12                       | 565                         | 565                               |
| P-4                   | Industrial Pl./Market Interceptor                     | 12-inch interceptor along Fred Waring Dr. from Industrial Pl. to Monroe St., sending flows down Market street                | Relieve Sola Street, Palo Verde Street, Avenue 44, and Avenue 45                         | 5, 6, 7              | 5 year       | New                   | No                        | 12                       | 967                         | 967                               |
| B-1                   | Ave 44/Palo Verde Interceptor and Upgrade             | Interceptor to divert flows to 15-inch pipe along Avenue 44 from Palo Verde Street, as well as upsizing of surrounding pipes | Relieve Palo Verde and Avenue 45                                                         | 6                    | Buildout     | Both                  | No                        | 12/18                    | 2,639/4,942                 | 7,581                             |
| B-2                   | Lago Vista Upgrade                                    | Upsizing of pipes along Lago Vista to relieve capacity issues                                                                | Relieve Lago Vista                                                                       | 11                   | Buildout     | Upgrade               | No                        | 15/18                    | 1697                        | 1697                              |

Note: Prefixes to project number stand for Existing (E), Planned (P), and Build-out (B).

\*These improvement projects are dependent upon the Requa Interceptor being built and in service.



## ES.8 CAPITAL IMPROVEMENT PROGRAM

The CIP project cost estimates in this section are planning level cost estimates. The estimate was prepared using a combination of parametric estimating factors and local experience in delivering projects similar to those that constitute VSD's CIP. Costs were based on MWH's experience with costs of similar projects in the Coachella Valley. The original costs were developed in March 2010. In order to estimate change in costs from March 2010 to June 2013, price indices from Engineering News Record (ENR) were used to create an adjustment factor that was applied to all costs. The ENR Construction Cost Index for March 2010 was 8671, while the same index has a value of 9542 for June 2013. Therefore, an adjustment factor of 1.1 (9542 divided by 8671) will be used to adjust historical price estimates, and all values are then rounded up to the nearest \$5 as a conservative estimate. All improvements are assumed to take place under asphalt road, and operations and maintenance costs are not included in this estimate.

**Table 8-12** presents a summary of all recommended projects and the associated total project costs. **Table 8-13** presents these project costs phased out for each planning phase, as well as gives a final cost estimate that includes a 30 percent contingency factor, a 15 percent engineering and administration estimate, and a 10 percent construction management factor. Based on these results, the total cost for all recommended improvements equals roughly \$49,390,400, where \$31,759,600 is the cost of replacement calculated in Section 6, and \$17,630,800 is the cost calculated in this section. It is of note that these costs are a conservative estimate, and in the case of those costs associated with the replacement program outlined in Section 6, it has been assumed that full replacement will be necessary for all pipes, while in fact many of the pipes may be able to be rehabilitated at a lower cost. Costs for pipes that needed replacement based on both capacity concerns and conditions concerns were only counted in the Section 8 costs above, and not counted again in the Section 6 costs.

**Table 8-12**  
**Summary of CIP Estimated Costs**

| Project No.                           | Project Name                                          | Total Construction (Const.) Cost (\$) | 30% Contingency (\$) | 15 % Eng. and Admin. (\$) | 10% Constr. Mgmt. (\$) | Rounded Total Cost (\$) |
|---------------------------------------|-------------------------------------------------------|---------------------------------------|----------------------|---------------------------|------------------------|-------------------------|
| E-1                                   | Requa Interceptor                                     | 7,236,300                             | 2,170,900            | 1,085,400                 | 723,600                | 11,216,300              |
| E-2                                   | Avenida Esmeralda Interceptor                         | 90,400                                | 27,100               | 13,600                    | 9,000                  | 140,100                 |
| E-3                                   | Monroe Interceptor Operational Change                 | N/A                                   | -                    | -                         | -                      | -                       |
| E-4                                   | Clinton Street Operational Change                     | N/A                                   | -                    | -                         | -                      | -                       |
| E-5                                   | Shields Interceptor                                   | 278,300                               | 83,500               | 41,700                    | 27,800                 | 431,400                 |
| E-6                                   | Avenue 48 West Upgrade                                | 823,100                               | 246,900              | 123,500                   | 82,300                 | 1,275,800               |
| P-1                                   | Arabia Interceptor/ Jackson Street Operational Change | 101,200                               | 30,400               | 15,200                    | 10,100                 | 156,900                 |
| P-2                                   | Highway 111 Interceptor                               | 576,900                               | 173,100              | 86,500                    | 57,700                 | 894,200                 |
| P-3                                   | Avenue 49 Interceptor                                 | 98,900                                | 29,700               | 14,800                    | 9,900                  | 153,300                 |
| P-4                                   | Industrial Pl./Market Interceptor                     | 169,300                               | 50,800               | 25,400                    | 16,900                 | 262,400                 |
| B-1                                   | Ave 44/Palo Verde Interceptor and Upgrade             | 1,576,300                             | 472,900              | 236,400                   | 157,600                | 2,443,300               |
| B-2                                   | Lago Vista Upgrade                                    | 424,000                               | 127,200              | 63,600                    | 42,400                 | 657,200                 |
| Pipe Replacement Costs from Section 6 |                                                       | 20,490,100                            | 6,147,000            | 3,073,500                 | 2,049,000              | 31,759,600              |
| <b>Total (Rounded)</b>                |                                                       | <b>31,864,800</b>                     | <b>9,559,400</b>     | <b>4,779,700</b>          | <b>3,186,500</b>       | <b>49,390,400</b>       |

Note: June 2013 dollars, costs rounded to nearest hundred.

**Table 8-13**  
**Phased CIP Costs**

| Scenario                                        | Existing          | 5-Year            | Build-Out        |
|-------------------------------------------------|-------------------|-------------------|------------------|
| Estimated Construction Cost from Section 8 (\$) | 8,428,100         | 946,300           | 2,000,300        |
| Estimated Construction Cost from Section 6 (\$) | 3,028,900         | 17,461,200        | 0                |
| <b>Subtotal</b>                                 | <b>11,457,000</b> | <b>18,407,500</b> | <b>2,000,300</b> |
| 30% Contingency (\$)                            | 3,437,100         | 5,522,300         | 600,100          |
| 15% Engineering and Administration Costs (\$)   | 1,718,600         | 2,761,100         | 300,000          |
| 10% Construction Management (\$)                | 1,145,700         | 1,840,800         | 200,000          |
| <b>Rounded Total Cost (\$)</b>                  | <b>17,758,400</b> | <b>28,531,600</b> | <b>3,100,400</b> |

Note: June 2013 dollars, costs rounded to nearest hundred.